



1. FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES, SEE DWG. E-1.
FOR INSTALLATION DETAILS, SEE DWG. E-2 AND E-4. FOR WIRING
DIAGRAMS, SEE DWGS. E-3 AND E-4.
2. REPLACE EXISTING STROBE WITH THE SHOWN CANDELA RATED STROBE,
AS SHOWN. EXISTING BACKBOX AND CONDUIT STUB CAN
BE UTILIZED IF IT IS SIMILAR TO THE TYPICAL STROBE OR COMBINATO
BOX. SEE INSTALLATION DETAIL "B" ON DWG. E-2.
3. ONLY AFTER INSTALLED STROBES ARE TESTED AND OPERATIONAL,
SHALL CONTRACTOR REMOVE EXISTING STROBE IN THE PRESENCE OF
THE ENGINEER. PATCH WALL TO MATCH EXISTING WALL FINISH.
4. SINCE FIRE ALARM CIRCUIT LENGTH IS CRITICAL, ROUTING AND
INSTALLATION OF ALL FIRE ALARM CIRCUITS SHALL BE AS SHOWN
ON DRAWING.
5. DISCONNECT AND ABANDON EXISTING STROBE CIRCUITS IN CEILING.
TAPE ENDS OF ABANDONED CONDUCTORS AND TAG AS ABANDONED.
THIS WORK SHALL BE DONE IN THE PRESENCE OF THE ENGINEER.

DATE 2/1/00 FA00
CONTRACT ENGINE ARCH.
DATE 2/18/00
ENGINEERING PROGRAM MC

ENGINEERING PROGRAM MANAGER
WORLD TRADE

CHIEF ELECTRICAL ENGINEER

Title
FIRE ALARM SYSTEM
DEVICE UPGRADE
PHASE III
5 WTC 3rd,4th,5th & 6th FLO

4th FLOOR
STROBE LAYOUT
INSTALLATION AND
REMOVAL
SOUTH PART PLAN

WTC-861.573 E-04-4S
Contract Number Drawing Number